

## Wintergreen Trails Well Data

**Site description:** on north side of Highway 70 approximately 4.5 miles east of Fifield, WI, Park Falls Unit.

**Local name:** Wintergreen Trails well

**Object ID in database (PF\_LocWCRs\_WGNHS\_2016):** 1017

**WGNHS WCR image number:** PR1131

**Location:** SESW Section 2, T 39N, R1E

**Top of casing elevation:** 1547 feet above MSL (taken from DEM)

**Drilled:** 1979

**Total depth:** 74 feet

**Cased to:** 70 feet; screened 70 to 74 feet.

**Depth to static water:** 38 feet reported by driller (August, 1979); 38.9 feet below top of casing measured on June 1, 2011.

Open to sand and gravel; bedrock not reached.

AUG 14 1979

Rev. 12-76

White Copy - Division's Copy  
Green Copy - Driller's Copy  
Yellow Copy - Owner's Copy

1. COUNTY		CHECK (✓) ONE:		Name			
Price		<input checked="" type="checkbox"/> Town	<input type="checkbox"/> Village	<input type="checkbox"/> City	Fifield		
2. LOCATION		1/4 Section	Section	Township	Range		
SE SW		2	39N	1E			
OR - Grid or Street No.		Street Name		3. NAME <input type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE			
AND - If available subdivision name, lot & block No.				U.S. Forest Service			
				ADDRESS			
				POST OFFICE			
				Park Falls, Wis.			
4. Distance in feet from well to nearest: (Record answer in appropriate block)		Building	Sanitary Bldg. Drain	Sanitary Bldg. Sewer	Floor Drain Connected To:		
		C.I.	Other	C.I.	Other		
		C.I. Sewer	Other Sewer	C.I.	Other		
Street Sewer		Other Sewers	Foundation	Drain Connected to:	Sewage Sump		
San.		Storm	C.I.	Other	C.I.		
			Sewer	Sewage Sump	Clearwater Sump		
			Clearwater Dr.	Clearwater Sump	Septic Tank		
					Holding Tank		
					Sewage Absorption Unit		
					Seepage Pit		
					Seepage Bed		
					Seepage Trench		
Privy		Pet Waste Pit	Pit: Nonconforming Existing	Subsurface Pumproom	Barn Gutter		
100			Well Pump Tank	Nonconforming Existing	Animal Barn Pen		
					Animal Yard		
					Silo With Pit		
					Glass Lined Storage Facility		
					Silo w/o Pit		
					Earthen Silage Storage Trench Or Pit		
Temporary Manure Stack		Watertight Liquid Manure Tank	Solid Manure Storage Structure	Subsurface Gasoline or Oil Tank	Waste Pond or Land Disposal Unit (Specify Type)		
					Other (Give Description)		
5. Well is intended to supply water for:		Flambeau Trails					
6. DRILLHOLE		9. FORMATIONS					
Dia. (in.)		From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	
10		Surface	20	Muddy fine sand		Surface	66
6		20	74	Hardpan and stones		66	68
				Sand and gravel		68	74
7. CASING, LINER, CURBING AND SCREEN							
Material, Weight, Specification & Method of Assembly		From (ft.)		To (ft.)			
6 new blk stl t&c 19.45		Surface		70			
API 5L USS							
6 Slot # 30 S.S. Screen		70		74			
8. GROUT OR OTHER SEALING MATERIAL							
Kind		From (ft.)		To (ft.)			
Cement		Surface		20			
11. MISCELLANEOUS DATA							
Yield Test: 3		Hrs. at 6		GPM			
Depth from surface to normal water level 38		Ft.		Well is terminated 16		inches	
Depth of water level when pumping 58		Ft.		Well disinfected upon completion		Yes No	
Stabilized Yes No				Well sealed watertight upon completion		Yes No	
Water sample sent to Wis App Lab. # 59 RRR MK		laboratory on August 8		19 79			
Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.							
Signature William D. Burned		Complete Mail Address D.S.L. malfor				plot 3066011	
Registered Well Driller							